



Adi M. Pour, Ph.D.
Health Director
(402) 444-7471
(402) 444-6267 fax

November 10, 2004

Access Medicaid Program
(402) 595-3870

Business Administration
(402) 444-7216

Child Care Nurse Consultant
(402) 444-6426

Epidemiology
(402) 444-7214

Food and Drink
(402) 444-7480

Health Data
(402) 444-7213

Health Promotion
(402) 444-7475

Lead Prevention Program
(402) 444-7825

Public Health Nursing
(402) 444-6427

Sanitation Control
(402) 444-7481

Sanitary Engineering
(402) 444-7485

Vital Statistics
(402) 444-7204

WIC
(402) 444-1770

Health Center Location:
42nd & Woolworth Avenue
Omaha, NE 68105

Immunizations
(402) 444-6163

Dental Services
(402) 444-7349

Laboratory Services
(402) 444-7496

STD Control
(402) 444-7750

Travel Clinic
(402) 444-7207

MEMO

To: CAG
From: Adi M. Pour, Ph.D., Health Director
Date: November 10, 2004

RE: Water testing for lead

MUD took 51 water samples in the City of Omaha in June 2004 to be in compliance with the lead/copper rule.

7 samples were taken at addresses that are in the area that comprises the Omaha Lead Site.

Results were:

- 4.82 ug/L
- 3.4 ug/L
- 2.43 ug/L
- 1.74 ug/L
- 1.7 ug/L
- 1.19 ug/L
- 1.12 ug/L

Range: 1.12 – 4.82 ug/L

City of Omaha range: 0 – 6.41 ug/L

US EPA action level for lead is 0.015 milligrams per liter (mg/L) or 15 micrograms per liter (ug/L).